



Haverhill

Lisa DeMeo, City Engineer/Tree Warden
Phone: 978-374-2335
ldemeo@haverhillma.gov

Review-Utility Company Request for New Conduit/Pole Location

Applicant Information

Project Address 9 Middlesex St

Utility (circle one)

Gas **Electric** Telephone Other

Reason: Install Temp Pole 0-50 35' East of Pole 1

Date Submitted 7/22/2026

Review done by LED

Sidewalk Material

Concrete

Asphalt

Other

Note: Material to be replaced in-kind (concrete in full panels)

Sidewalk vaults present?

Y

N

Work on street under a paving moratorium?

Y

N

Is this location within a flood plain?

Y

N

Are ADA requirements being met?

Y

N

Comments

- Install pole in grass buffer like others
- Proposed Pole location is within flood plain
 - Confirm Compliance with Conservation
- Remove spoils immediately

Outcome of Review

Approved

Approved with Comments

Denied

☐☒☐

Lisa E. DeMeo, P.E. City Engineer/Tree Warden

Lisa E De Meo, P.E.